



NOTES:

SEPARATION MANHOLE SHALL BE LOCATED WITHIN 5 TO 10 FEET OF THE PROPERTY LINE.

SEPARATION MANHOLE PIPE SHALL BE NON-REINFORCED CONCRETE PIPE (706.01) OR AN APPROVED EQUAL.

ALL MANHOLE JOINTS SHALL BE RESILIENT AND FLEXIBLE GASKET JOINTS WITH BUTYL MASTIC SEALS.

MINIMUM SEPARATION BETWEEN THE CROWN OF THE SANITARY PIPE AND THE BOTTOM OF THE STORM PIPE SHALL BE 6".

MANHOLE BOTTOM SHALL BE CHANNELED IN THE DIRECTION OF THE FLOW.

ALL CONCRETE SHALL BE CLASS "C".

THE
METROPOLITAN SEWER DISTRICT
OF
GREATER CINCINNATI
STANDARD
SEPARATION MANHOLE

NO SCALE

DATE: AUG., 2006

APPROVED:

[Signature]
SEWERS CHIEF ENGINEER

S.N.

ACC. NO. 49067