



**NOTES:**

ALL JOINTS SHALL BE FLEXIBLE ELASTOMERIC SEALS, ASTM D-3212  
 CLEANOUTS SHALL BE PLACED EVERY 200 FEET, AND AT BENDS 45° OR GREATER

THE  
 METROPOLITAN SEWER DISTRICT  
 OF  
 GREATER CINCINNATI  
**STANDARD**  
**TWO WAY CLEANOUT**  
**FOR BUILDING SEWERS**

NO SCALE DATE: AUG. 2011  
 APPROVED: *Ralph Christone*  
 SEWERS CHIEF ENGINEER

M.C.

ACC. NO. 61979