

INLET CHAMBER SHALL BE BUILT OF CONCRETE OR BRICK MASONRY IN ACCORDANCE WITH ODOT SPECIFICATION IN THE CITY SUPPLEMENT OR PRECAST, SEE REINFORCING STEEL NOTES ACC. NO. 49010

PIPES SHALL NOT ENTER WITHIN 8" OF CORNER


FOR STANDARD CASTINGS, SEE ACC. NO. 49020

SECTION B-B

CITY OF CINCINNATI
 METROPOLITAN SEWER DISTRICT
 STORMWATER MANAGEMENT UTILITY

**STANDARD
 SINGLE VALLEY INLET
 PLAN S.V.I.**

NO SCALE
 APPROVED

AUGUST, 2014

 SMU CHIEF ENGINEER

ACC. NO. 49019